

Requirements of permit for Hot Tub/Spa –

1. **Approved lockable safety cover (ASTM F 1346) or approved fence/gate**
2. **Must not be placed closer than five (5) feet to non-tempered glass**
3. **Do not place hot tub/spa under any existing overhead wires, or within 10ft. of wires**
4. **All receptacles within 20 feet of hot tub/spa must be GFCI protected**
5. **All metal parts must be bonded per the code requirements or meet manufacturers bonding requirements. No metal or metallic items within five (5) feet of hot tub/spa edge**
6. **Electrical disconnect must be within sight of hot tub/spa**
7. **No electrical equipment/devices within six (6) feet of hot tub/spa edge**
8. **Cannot be placed on a deck without engineering design**
9. **Installation must meet requirements of the International Swimming Pool & Spa Code and the International Residential Code**

Wiring Requirements – (This list is not all inclusive)

1. **All electric used in hot tub/spa installations must be in conduit/raceways and buried with the appropriate amount of fill.**
2. **Electric circuits that supply hot tubs/spas must be GFCI protected**
3. **Rigid Metal & Intermediate Metal conduit minimum burial depth is 6”.**
4. **Nonmetallic raceways listed for direct burial - minimum burial depth is 18”.**
5. **Wiring in conduit/raceways must be suitable for wet or damp locations and have a individual insulated grounding conductor run with the line & neutral wires**
6. **All electrical work must meet the IRC and/or the NEC**
7. **DO NOT USE “UF” WIRING TO SUPPLY HOT TUB/SPA EQUIPMENT**

The most recent editions of the International Codes as adopted by the state of Pennsylvania shall be used for compliance.